

**SPA OPERATIONS RECORDS: DAY TIME**

**Retain this record for a minimum of 1 year**

DATE/TIME (every 2 hrs)	Free Chlorine Or Total Bromine	pH	TEMP. (max. 104°F)	Combined Cl (DAILY)	Cyanuric Acid (DAILY)	Filter BW or New cartridge	ACTIONS TAKEN/COMMENTS Chemicals added - Amount
/ / Mon am							
/ / Mon am/pm							
/ / Mon am/pm				//////////	//////////		
/ / Mon pm				//////////	//////////		
/ / Tues am							
/ / Tues am/pm							
/ / Tues am/pm				//////////	//////////		
/ / Tues pm				//////////	//////////		
/ / Wed am							
/ / Wed am/pm							
/ / Wed am/pm				//////////	//////////		
/ / Wed pm				//////////	//////////		
/ / Thurs am							
/ / Thurs am/pm							
/ / Thurs. am/pm				//////////	//////////		
/ / Thurs pm				//////////	//////////		
/ / Fri am							
/ / Fri am/pm							
/ / Fri am/pm				//////////	//////////		
/ / Fri pm				//////////	//////////		
/ / Sat am							
/ / Sat am/pm							
/ / Sat am/pm				//////////	//////////		
/ / Sat pm				//////////	//////////		
/ / Sun am							
/ / Sun am/pm							
/ / Sun am/pm				//////////	//////////		
/ / Sun pm				//////////	//////////		

ACTION CODES: BW = Backwashed Filter S = Skimmer Cleaned DS = Drained Spa CS = Cleaned Spa Cls = Closed Spa

ADDITIONAL TESTS REQUIRED			MONTHLY TESTS	
DATE	CALCIUM HARDNESS 200–400 ppm recommended <b>When spa is refilled</b>	TOTAL ALKALINITY 80 –120 ppm - When spa is refilled & at least <b>once a week</b>	GFCI DATE -- Locations / /	BACTERIA SAMPLE DATE / /
/ /				Coliform
/ /				Pseudomonas aeruginosa